

## OFFICIAL RECALL NOTICE

18<sup>th</sup> August 2016



**Product Code:** C02EA **Description:** Aluminium CommanderEdge Range 2kg CO2 Extinguisher (as pictured above)

Checkfire would like to inform the Fire Extinguisher trade of a possible product failure (where the valve has ejected from the cylinder whilst under pressure). Investigation has proved that in three cases there is Pb gathering in the valve raw material. **The batch in question has a manufacture date of 2016/01.** Where these extinguishers are identified please telephone Cameron Robins or Darren Lucas on 029 2086 8333 or email [cameron@checkfire.co.uk](mailto:cameron@checkfire.co.uk) or [darren@checkfire.co.uk](mailto:darren@checkfire.co.uk) and appropriate action will be taken.

No other batches were affected by this defect.

Signed

**Cameron Robins**  
**Purchasing Manager**  
For an on behalf of **CHECKFIRE**